

High-Current, Line-Voltage-Rated Relays • Large Removable Connector



- Lighting Control
- Door Locks
- Remote Gate Control
- Motor Control
- Pumps



a division of Xytronix Research & Design, Inc. located in Nibley, Utah, USA © 2014 Xytronix Research and Design, Inc.

	X-11s User Manual Revisions
Revision	Description
1.0	Initial release

Section 1: Introduction

The X-11s[™] 2-relay expansion module is used in conjunction with the X-600M[™] controller. The X-11s has two high-current relays. Both relays have Form-C contacts (SPDT). A rugged, high-current connector provides connections to the relays. One or more X-11s expansion modules can be connected to a X-600M control module with a ribbon cable. The ribbon cable provides both power and communications to the expansion modules.

The X-600M is a multifunction web-enabled industrial I/O controller. It performs control, logic, and monitoring functions similar to that of a Programmable Logic Controller (PLC). However, unlike a PLC, the X-600M is designed for web-based applications from the ground up. No add-on software or hardware is required. The X-600M can be fully configured, programmed and tested using its built-in web server. The web setup pages are intuitive and easy to use and do not require special programming skills.

The X-600M together with expansion modules such as the X-11s provide an easy, flexible and reliable way to monitor and control systems and devices over a network. The X-11s is suitable for use with loads which require line voltages and high current such as pumps, motors, lights and heaters.



1.1 Connectors & Indicators

Relays

The X-11s has two, high-current, line-voltage-rated relays. It has a large, 6-position plug-in screw terminal connector that provides connections to the relays. The connector can be released by pushing the two orange latches forward, then pulling on the connector housing while squeezing the latches. Terminals are provided for the *Common, Normally Open*, and *Normally Closed* contacts. The connector terminals are wired directly to the internal relays with no internal fuse or other over current protection. The relays are isolated from all other circuits inside and from each other. When a relay coil is energized, the *NO* (Normally Open) contact is closed and the *NC* (Normally Closed) contact is open. The load device that is connected to the relay contacts may be on or off when the coil is energized depending on which contacts are connected to the load.

Expansion Bus

The expansion bus allows for a family of expansion modules to be connected directly to the X-600M without the need for an Ethernet switch. The cable can be a daisy chain with multiple connectors. The

ribbon cable expansion bus provides both power and communications connections.

Power Supply

The expansion bus can provide up to 1.7 Amps for powering up to 32 expansion modules; however, the maximum number of expansion modules depends on the module type and power source attached to the X-600M. The X-11s requires relative high current to operate the relays and the 1.7 Amp limit will be reached before the 32-module limit.

The X-11s employs modern switch-mode power supply. With this type of power supply the current draw <u>decreases</u> as the voltage increases; therefore, you can add more expansion modules by using a 24-volt power supply than you can with a 12-volt power supply. See the *X*-600M User Manual for more details.

Indicators

The green, power LED indicator is illuminated whenever the module is powered. To identify the module during installation, the X-600M can send a blink command which will cause the power LED to blink for three seconds. The two, yellow LEDs indicate the status of the relays - Each LED illuminates when its respective relay coil is energized.

1.2 Part Numbers and Accessories

Device	Description	Part Number
X-11s	2-Relay expansion module	X-11s
Spare Connector	6-position, screw terminal connector with latches	X-1778104

Section 2: Installation and Connections

Installation consists of mounting the X-11s and connecting it to an X-600M controller with a 10-conductor ribbon cable. Programming and testing is done by using a web browser to configure the web pages, inputs, and outputs for your specific needs.

2.1 Installation Guidelines

- This unit must be installed by qualified personnel. In the case of line-voltage connections, a licensed electrician should be employed.
- This unit must not be installed in unprotected outdoor locations.
- This unit must not be used for medical, life saving purposes, or for any purpose where its failure could cause serious injury or the loss of life.
- This unit must not be used in any way where its function or failure could cause significant loss or property damage.

This equipment is tested to UL 61010-1 safety requirements for equipment to be supplied from the building wiring (i.e. thru a circuit breaker). It is not rated for installation within or as part of the circuit breaker panel. When used to control AC line voltages, the X-11s must be mounted and protected in a suitable electrical enclosure.

2.2 Mounting

The X-11s can be mounted to a standard (35mm by 7.55mm) DIN-Rail. Normally expansion modules are mounted to the left side (embossed logo side of the enclosure) of the X-600M controller so that the ribbon cable doesn't cover the power connector. The X-11s should be located in a clean, dry location where it is protected from the elements. Ventilation is recommend for installations where high ambient air temperatures are expected to be high. See *Appendix D: Mechanical Information* for additional mechanical details.



2.2.1 DIN-Rail Mounting

Attach the X-600M to the DIN-Rail by hooking the top hook on the back of the enclosure to the DIN-Rail and then snap the bottom hook into place. To remove the X-600M from the DIN-Rail, use a flat-head screwdriver. Insert the screw driver into the notch in the release tab and pry against the enclosure to release the bottom hook.

2.3 Making Connections

CAUTION: Make sure the power is shut off before making connections

CAUTION: This unit should be installed by a qualified technician.

CAUTION: Miswiring or misconfiguration could cause permanent damage to the X-11s, the equipment to which it is connected, or both.

2.3.1 Connecting the X-11s to the Expansion Bus

Connect the X-11s to the expansion bus using a ribbon cable (sold separately). The number of modules that are connected to the expansion bus are dependent upon the type of module, the power supply used, and the number and type of other modules connected to the expansion bus. This can be calculated by adding up the total amount of current required for each module (with all relays, inputs, etc. on) at the voltage provided by the power supply. That number is called the expansion bus current (make sure the expansion bus current does not exceed 1.7 Amps). Next, add the expansion bus current to the current required by the X-600M. That is the total current required. Make sure the power supply used has an output current rating that is higher than the total current required. Some extra margin is recommended.

For example, using the 24V 1.75Amp power supply that we offer:

At 24V, the X-600M draws 80mA which leaves 1.67A for the expansion bus (1.75A - 0.080A = 1.67A).

Each X-11s module requires up to 105mA at 24V. If we divide 1.67A by 0.105A we get 15.9A. This means ... With a 24V, 1.75A power supply, the maximum number of X-11s expansion modules that can be connected to the expansion bus is 15 (with no other types of expansion modules connected).

<u>Note</u>: A larger power supply and power injectors can be used to attach more modules to the bus (see the X-600M users manual for details).

2.3.2 Connecting Relays

A removable terminal connector is provided for making the power connections. The correct wiring procedure is as follows:

- 1. Make sure power is turned off.
- 2. Remove the terminal connector from the X-11s and make wiring connections to the terminals. This technique avoids stressing the internal components while torquing the screws.
- 3. Reconnect the terminal connector.
- 4. Apply power.

It is recommended that any load (device to be controlled) not be connected to the expansion modules until after the X-600M has been configured and tested. By doing this, wiring and configuration mistakes will not cause the load device to turn on unexpectedly.

Make certain the wires are properly inserted into to the terminals and that the screws are tight.

Wire Specification:

Use wire rated for 90°C (min) for connections to the terminal blocks

Connector Specifications:

Туре:	6-position, removable, 7.62 mm pitch, with tool-free snap-lock latches
Stripping Length:	10mm
Connection capacity:	6mm ² stranded, 10mm ² solid
Conductor minimum:	24AWG (UL/CUL)
Conductor maximum:	8 AWG (UL/CUL)
Conductor Type:	Copper
Tightening torque:	0.5 Nm (min), 0.8 Nm (max)

Section 3: Example Applications

3.1 Control a device over an IP network

The illustration below shows a simple example of how to use the X-11s to control a device over an IP network. The device to be controlled is wired in series with the relay contacts.

Note: A fuse or circuit breaker is shown to limit current overload.



3.2 High Current Relay

The illustration below shows an example of how the X-11s is used to control an AC motor. A high-current relay is used to switch the load current to the motor. In this example a MOV (Metal Oxide Varistor) is used to help protect the relay contacts of the X-11s from arc damage. Under normal conditions the resistance of the MOV is very high. When a spike or surge occurs the resistance of the MOV drops and shunts the high voltage transients.



Section 4: Configuration and Setup

4.1 Setup Example

The Quick Start Demo

After making the power and Ethernet connections, the X-600M can automatically scan for the presence of any ControlByWeb[™] Ethernet devices (on the same sub-net) and also for any expansion modules connected to the X-600M via the ribbon-cable connector. It also automatically creates a dashboard web page and populates it with all of the resources (components) supported by the Ethernet devices and expansion modules. This makes it easy to start experimenting with the web page's user interface and to try out the relays and sensors.

To quickly add a device do the following:

1. Click on the **Devices** menu tab to pull up the *Devices Overview* page. Then click on the **Find New Devices** button to scan the expansion bus and the local network for ControlByWeb devices and expansion modules.

	Commit Chances A	Welcome: Administra Abandon Changes Log
System		
Network	Devices Add, edit, and delete devices that are attached to the X-600M either through the expansion bus or through the Ethernet network	. Devices must be
Devices	added before setting up I/O, Logic, or Dashboards	
Devices	added before setting up I/O, Logic, or Dashboards	
	added before setting up I/O, Logic, or Dashboards Device List Find New Devices	
<u>►</u> 1/0		Add New Device

2. In this example we are going to add an *X-11s* | *2 Relay expansion module*. Click the **Add** button for the X-11s.

⊢ → C 🗋 192.168.	.1.2/setup.html						 \$2
							2
						0	Welcome: Administr nges Abandon Changes Lo
						Commit Char	iges Abandon Changes Loj
System	Devices	Find Devices					
Network	-	atically detected new devices.					
Devices	List of datome	and any accords new acrises.					
<u>vo</u>							
Control/Logic	New Devices Found	Rescan Back					
Logging	Show 10 \$ entr	ies					
	Model	Serial Number	Comm Type	Address	Description	Name	Select
1			SERIAL	AUTO_GENERATE	AUTO_GENERATE	AUTO_GENERATE	Add
Edit Dashboards	X-15S	00000001					
Edit Dashboards	X-15S X-11S	00000001 0000004f	SERIAL	AUTO_GENERATE	AUTO_GENERATE	AUTO_GENERATE	Add
			SERIAL	AUTO_GENERATE AUTO_GENERATE	AUTO_GENERATE	AUTO_GENERATE	Add
	X-11S	0000004f					
Edit Dashboards	X-11S X-16S	0000004f 0000006e	SERIAL	AUTO_GENERATE	AUTO_GENERATE	AUTO_GENERATE	Add

3. In the *Select* column, click the checkboxes of the I/O components you would like to configure and select the **Create Device Widget** checkbox (This will display the status of the I/O on the Dashboard).

○ ○ ○	×			±2
← → C 🗋 192.168	.1.2/setup.html			☆ =
	0 0 0 192.168.1.2/popup	X600M		Welcome: Administrator
System System Network Devices		tve Add I/O 12 Relay Slave (0000004f). Please see below the list fo	or a description of each field.	
↓ 1/0	I/O Type	I/O Description	I/O Name Select	
Control/Logic	Relay 1	AUTO_GENERATE	AUTO_GENERATE	
	Relay 2 Showing 1 to 2 of 2 entr	AUTO_GENERATE		Select
Edit Dashboards	I/O Description: Text c spaces and the maximu I/O Name: This is a unit must start with an alpha nothing is entered a nam Select: Each I/O that is	create device widget the type and reference number of each input and output an be entered here to identify the I/O in a format that is number of chancelsens is 77?. If nothing is entered a que name given to each I/O. This name is used to refe betic (not a number) character and cannot include span en will automatically be generated. 	easy to understand and recognize. It can include description will be automatically generated. rence the I/O when writing scripts. This name ses. The name can be up to ??? characters long. If ase and can then be used by the X-600M. For	Add Add Previous Next
Status: Ready		For product support go to www.ControlBy	Web.com Xyt	ronix Research & Design, Inc.

Click Add Checked I/O to submit these changes.

4. Click Commit Settings - Once clicked, the X-600M begins to monitor the newly added device.

						Commit	Welcome: Administra Changes A) andon Changes Log
System	Device:						
Devices		and delete devices that a ting up I/O, Logic, or Dash		A either through the	expansion bus	s or through the Ethernet ne	twork. Devices must be added
: VO							
I/O , Control/Logic	Device List	Find New Devices					
Control/Logic	Device List	Find New Devices	Address	∳ Port ∳	Model	🔷 Serial Number 🍦	🔿 Add New Dev
				∳ Port ∳ n/a	Model X-600M	Serial Number 00:0c:c8:00:00:72	Add New Dev

5. On the main menu, click the **View Dashboards** menu tab. The **View Dashboards** page shows a display similar to what users will see when accessing the X-600M's control page. A button and status display for both relays should appear.

Use this page to test and debug the dashboards, panels, widgets and components in real time. A pulldown menu allows access to other dashboards. Within minutes you can experience the power and flexibility of the dashboard's user interface and experiment/test the buttons, sliders, and data entry boxes to meet your needs for your specific application.

●	×	κ ²
← → C 🗋 192.168.1.2	/setup.html	☆ =
		Welcome: Administrator Commit Changes Abandon Changes Logout
🖋 System		
Network	X600M - Dashboard 1	
Devices	2 Relay Slave (0000004f)	
↓ I/O	Relay 1: On On Off	
Control/Logic		
Logging	Relay 2: Off On Off	
Edit Dashboards		
View Dashboards		

Appendix A: Specifications

Power Requirements

Input Voltage: 9-28 VDC (power is supplied via the X-600M controller, 24V recommended) Current: See table below for typical values at 25°C

Power Supply	Relays OFF	Relays ON
9 VDC	15 mA	260 mA
12 VDC	12 mA	196 mA
24 VDC	7 mA	105 mA

Relays

Number of relays: 2

Relay Contacts

Load Type: Contact Form:	General purpose SPDT (form 1C)
Contact Material:	Silver Nickel
Max Voltage:	277 VAC (general purpose)
_	30 VDC (NC contact, resistive)
Max Current:	20A
Electrical Life:	100K cycles, typical @ full rated load (higher with smaller load)
Mechanical Life:	10M cycles, typical
Environmental Rating:	Over voltage Category II, Pollution Degree 2
C C	· · · · ·
<u> </u>	

Control Options:	On/Off or Pulsed
Pulse Timer Duration:	100ms to 86400 Seconds (1-day)

Relay Connector

Туре:	6-position, removable, 7.62 mm pitch, with tool-free snap-lock latches
Connection wire:	Use wire rated for 90°C (min) for connections to the terminal blocks
Stripping Length:	10mm
Connection capacity:	6mm ² stranded, 10mm ² solid
Conductor minimum:	24AWG (UL/CUL)
Conductor maximum:	8 AWG (UL/CUL)
Conductor Type:	Copper
Tightening torque:	0.5 Nm (min), 0.8 Nm (max)

(Replacement part number, Phoenix Contact 1778104)

Expansion Connector:

Connector:	Ribbon cable, 2x5-position, polarized 0.100" pitch
Communications:	RS-485

LED Indicators

Green:	Power On
Yellow:	Relay1, Relay 2

Environmental

Indoor use or NEMA-4	protected location
Altitude:	up to 2000m

Operating Temperature:	-40°C to 65.5°C (-40°F to 150°F)
Storage Temperature:	-40°C to 85°C (-40°F to 185°F)
Humidity:	5-95%, non-condensing

Mechanical

Size:	1.41 x 3.88 x 3.1 in. (35.7 x 98.5 x 78 mm), (not including connector)
Weight:	4.8 oz (136 g)

Electromagnetic Compliance

IEC CISPR 22, CISPR 24 CC 47CFR15 (Class B) EN55024 ITE Immunity (2010) EN55022 Emissions (2010)

Product Safety Compliance

UL 61010-1 (Electrical Equipment for Measurement, Control, and Laboratory Use)

CE



Appendix B: Trademark and Copyright Information

This document is Copyright ©2014 by Xytronix Research & Design, Inc. All rights reserved.

X-600M[™], WebRelay[™], ControlByWeb[™], and Xytronix Research & Design[™] are trademarks of Xytronix Research & Design, Inc. 2005-2014.

All other trademarks are the property of their respective owners.

All parts of this product and design including but not limited to firmware, hardware design, schematics, PCB layout, concept, graphics, users manual, etc., are property of Xytronix Research & Design, Inc. ©2005-2014. X-600M may not be opened, disassembled, copied or reverse-engineered.

No part of this manual may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying or scanning, for any purpose other than the personal use by the purchaser of this product. Xytronix Research & Design, Inc., assumes no responsibility for any errors that may appear in this document.

Whereas reasonable effort has been made to make the information in this document as useful and accurate as possible, Xytronix Research & Design, Inc. assumes no responsibility for the application, usefulness, or completeness of the information contained herein. Under no circumstance will Xytronix Research & Design, Inc. be responsible or liable for any damages or losses including direct, indirect, special, incidental, or consequential damages or losses arising from either the use of any information contained within this manual or the use of any products or services referenced in this manual.

Xytronix Research & Design, Inc. reserves the right to change any product's features, specifications, documentation, warranties, fee schedules, and conditions at any time and without notice.

Appendix C: Warranty

This Xytronix Research & Design, Inc. product has a warranty against defects in material and workmanship for a period of one year from the date of shipment. During the warranty period, Xytronix Research & Design, Inc. will, at its option, either repair or replace products that prove to be defective. This warranty is extended to the original purchaser of the equipment only.

For warranty service or repair, the product must be properly packaged, and returned to Xytronix Research & Design, Inc. The purchaser shall prepay all charges for shipping to Xytronix Research & Design, Inc., and Xytronix Research & Design, Inc. will pay the shipping charges to return the product to the purchaser as long as the product is shipped within the United States. If the product is shipped outside of the United States, the purchaser shall pay all shipping charges, duties, and taxes.

Limitation

The foregoing warranty shall not apply to defects or damage resulting from improper use or misuse, unauthorized repair, tampering, modification, improper connection, or operation outside the electrical/environmental specifications for the product. Further, the warranty does not cover Acts of God, such as fire, flood, hurricanes, and tornadoes. This warranty does not cover damage to property, equipment, direct, indirect, consequential, or incidental damage (including damage for loss of business profit, business interruption, loss of data, and the like) arising out of the use or misuse of this product.

UNDER NO CIRCUMSTANCES WILL THE LIABILITY OF XYTRONIX RESEARCH & DESIGN, INC. TO THE PURCHASER OR ANY OTHER PARTY EXCEED THE ORIGINAL PURCHASE PRICE OF THE PRODUCT, REGARDLESS OF THE FORM OF THE CLAIM. No other warranty is expressed or implied. Xytronix Research & Design, Inc. specifically disclaims the implied warranties or merchantability and fitness for a particular purpose. Some jurisdictions may not allow the exclusion of limitation of liability for consequential or incidental damage.

Appendix D: FCC Statement

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions:

- This device may not cause harmful interference.
- This device must accept any interference received, including interference that may cause undesired operation.

Warning

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause interference to radio communications. There is no guarantee, however, that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into a relay on a circuit different from where the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

Notice

Changes or modification not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

Appendix E: Mechanical Dimensions



